

HEALTH AND INDOOR AIR QUALITY IN ELDERLY CARE CENTERS IN PORTUGAL

Ana MENDES¹, Livia AGUIAR¹, Cristiana PEREIRA¹, Paula NEVES¹, Susana SILVA¹, Diana MENDES¹, Rossana MORONI², Stefano BONASSI², João Paulo TEIXEIRA^{1*}

¹Environmental Health Department, Portuguese National Health Institute Doutor Ricardo Jorge, Rua Alexandre Herculano, 321, 4000-055 Porto, Portugal

²IRCCS San Raffaele S.p.A, Via di Val Cannuta, 247, 00166 Rome, Italy

* Corresponding email: jpft12@gmail.com

Keywords: Indoor air quality, Thermal comfort, Elderly care centers, Respiratory health.

INTRODUCTION

According to the United Nations estimates, the total number of people aged 65 years and older was 506 million in 2008 and is anticipated to double to 1.3 billion by 2040, accounting for the 14 percent of total global population. This trend explains the increasing demand of long-term care services (Damiani et al., 2009) such as elderly care centers (ECCs). Furthermore, considering that persons who are 65 years or older, often spend a considerable portion of their lives indoors, it is clear that the possibility that adverse indoor climate can influence their health status cannot be ignored. This paper presents results which have been produced within the GERIA ongoing project ‘Geriatric study in Portugal on Health Effects of Air Quality in Elderly Care Centers’, by measuring and characterizing indoor air quality (IAQ) and thermal comfort (TC) in 22 ECCs in Porto, Portugal. The aim of the study was to evaluate 1) the IAQ and TC in a representative sample of ECCs in Porto as compared with international standards, 2) to study the variability among different spaces within single ECCs, and 3) how buildings characteristics may affect the extent of indoor air pollution or thermal regulation.




METHODOLOGIES

Of a total of 58 ECCs, located in Porto urban area, 38% (n =22) accepted to participate in this study. Indoor environmental parameters were measured twice, during winter and summer, starting from November 2011 till August 2013, in 141 ECCs rooms within dining rooms, drawing rooms, medical offices and bedrooms. These areas were assessed for IAQ chemical (CO₂, CO, Formaldehyde, TVOC, PM₁₀, PM_{2.5}) and biological contaminants (total bacteria and fungi). TC parameters were measured following ISO 7730:2005 (PMV and PPD indexes). The monitoring phase included daytime air sampling (starting at 10 am and continuing for at least 4 h to 8h during normal activities) conducted discretely to minimize nuisance to normal resident’s activities. A walk-through building questionnaire was performed prior the monitoring and outdoor samples were also collected for comparison. Classical statistical methods were used to estimate means, medians and frequencies (percentages) in order to obtain insight into the ECCs characteristics and environmental monitoring results within and between buildings. The variables were tested for normality with Shapiro-Wilk test. Mann-Whitney (U) test and Kruskal-Wallis (H) for independent samples were conducted for seasonal effects assessment, indoor/outdoor and within buildings location differences. It was

also performed a student t-test for the variable ‘air temperature’. A 0.05 level of significance was used for all analyses. All data were analyzed using IBM SPSS 21.0.

RESULTS AND DISCUSSION

The 22 ECCs were located in the urban area of Porto city, most of them (n=17) in heavy traffic areas. A total of 716 elderly lived in these centers with a range of 7 to 136 occupants per building. As regards construction characteristic, 66% were an adaptation to ECC of an existing residential building, and 40% were also developing activities of day care centers for elderly. Most of them were built in stone masonry construction (49%) with single pane windows (87%). Only 30% had roof and walls insulation, while 61% of the sampled presented condensations and infiltrations along walls and roofs inside the buildings. All ECCs were smoke-free. Regarding the ventilation type, 87% had mixed ventilation (natural ventilation in the rooms along with exhaustion systems in the kitchen and bathrooms) while 13% had only natural ventilation in all the indoor areas. The building characteristics ‘Insulation’, ‘Heating Ventilation’ and ‘Windows frames’ appear to be the most influential parameters on IAQ and TC. The environmental parameters most commonly affected by building characteristics are the ‘Bacteria’, ‘Fungi’, ‘Temperature’, Relative Humidity’, and ‘PPD index’ (Table 1).

Table 1. Building characteristics in the indoor environmental evaluation (significant differences by building variable and environmental evaluation:  p < 0.001;  p < 0.01;  p < 0.05)

Parameters												
Buildings Variables	<i>PM₁₀</i>	<i>PM_{2.5}</i>	<i>TVOC</i>	<i>HCHO</i>	<i>Bacteria</i>	<i>Fungi</i>	<i>CO</i>	<i>CO₂</i>	<i>Temp.</i>	<i>RH</i>	<i>PPD</i>	<i>PMV</i>
Adapted to ECC												
Building occupation												
Sources of pollution												
Walls												
Insulation												
Roof lining												
Ventilation type												
Heating ventilation												
Building pathologies												
Windows type												
Sealants												
Type sealants												
Windows frames												
Glass type												
Flooring												

Regarding the indoor air suspended particles, *PM₁₀* presents significant differences depending on windows characteristics, whereas *PM_{2.5}* is also affected by ventilation characteristics, type of roof lining and insulation, and by the presence of architectural modification to adapt the

building to the use as ECC ('adapted to ECC'). TVOC is higher if the building is close to sources of pollution, and depends also by building insulation, ventilation characteristics, windows, walls and floor characteristics. Formaldehyde is significantly affected by the condition of 'adapted to ECC', by 'insulation' and type of flooring. Similarly, CO is higher in building 'adapted to ECC' and is modified by insulation and roof lining characteristics. CO₂ shows differences also depending upon the presence of windows sealants and the type of these sealants. The presence of bacteria depends on heating/ventilation or the presence of building pathologies. Fungi concentrations is associated to 'adapted to ECC', 'sources of pollution', 'insulation', roof and windows characteristics, and building pathologies such as infiltrations and condensations. Concerning the TC, temperature is modified by essentially all building characteristics except by the type of ventilation, the building pathologies, and the windows sealant characteristics. RH varies according to the building purpose and occupation, the insulation and ventilation characteristics, and roof, walls, floor and windows features. These findings are overlapping those of PMV and PPD indexes, with the exception of the glass-type variable for PPD.

The overall PM_{2.5} mean concentration of the 22 ECC was above international reference levels (35 µg/m³) in both seasons. These findings showed as this parameters is critical for air quality, both for its sensitivity and for its possible influence on human health. Other studies (Bentayeb et al., 2013; Wang, Bi, Sheng, & Fu, 2006) have found, high levels of PM_{2.5} in similar indoor environments, and the link with lung function (Lee, Son, & Cho, 2007) and respiratory diseases such as COPD (Liu et al., 2007; Osman et al., 2007) has been quite demonstrated. Although all the other indoor air pollutants were within the reference levels peak values of PM₁₀, TVOC, CO₂, bacteria and fungi exceeded the reference levels, compromising indoor air comfort and worsening the already existent respiratory chronic diseases. TVOC, Bacteria, CO and CO₂ showed significantly higher indoor levels compared to outdoor, in both seasons. Indoor PM₁₀, TVOC, Bacteria and CO₂ present significant differences between seasons ($p < 0.01$). TVOC, bacteria and CO₂ show significant variation between ECC rooms ($p < 0.01$) and 4% of fungi samples were positive for pathogenic *Aspergillus species*. The winter PMV index is below references and between the 'slightly cool' and 'cool' (-2) points in the thermal sensation scale, which may potentiate respiratory tract infections. PPD and PMV indexes show significant differences by room and by season ($p < 0.01$).

CONCLUSIONS

Our study suggested that attention is needed to PM_{2.5} particle fraction, as well as, peak concentrations and fungi species that might compromised IAQ comfort. To prevent low indoor temperatures and discomfort, especially on winter season, simple measures could provide health benefits to ECC residents and workers, such as insulating ceilings, walls, and windows, maintaining natural and passive ventilation, solutions that are common in Portugal due to the advantage of the country's generally mild weather.

ACKNOWLEDGEMENT

Our current research is supported by GERIA Project (www.geria.webnode.com): PTDC/SAU-SAP/116563/2010 and a PhD Grant (SFRH/BD/72399/2010) from Foundation for Science and Technology (Fundação para a Ciência e Tecnologia - FCT).

REFERENCES

- Bentayeb, M., Simoni, M., Norback, D., Baldacci, S., Maio, S., Viegi, G., & Annesi-Maesano, I. (2013). Indoor air pollution and respiratory health in the elderly. *J Environ Sci Health A Tox Hazard Subst Environ Eng*, 48(14), 1783-1789. doi: 10.1080/10934529.2013.826052
- Damiani, G., Colosimo, S. C., Sicuro, L., Burgio, A., Battisti, A., Solipaca, A., . . . Ricciardi, W. (2009). An ecological study on the relationship between supply of beds in long-term care institutions in Italy and potential care needs for the elderly. *BMC Health Serv Res*, 9, 174. doi: 10.1186/1472-6963-9-174
- Lee, J. T., Son, J. Y., & Cho, Y. S. (2007). The adverse effects of fine particle air pollution on respiratory function in the elderly. *Sci. Total Environ.*, 385, 28–36.
- Liu, S., Zhou, Y., Wang, X., Wang, D., Lu, J., Zheng, J., . . . Ran, P. (2007). Biomass fuels are the probable risk factor for chronic obstructive pulmonary disease in rural South China. *Thorax*, 62, 889–897.
- Osman, L. M., Douglas, J. G., Garden, C., Reglitz, K., Lyon, J., Gordon, S., & Ayres, J. G. (2007). Indoor air quality in homes of patients with chronic obstructive pulmonary disease. *Am. J. Respir. Crit. Care Med.*, 176, 465–472.
- Wang, X., Bi, X., Sheng, G., & Fu, J. (2006). Hospital indoor PM10/PM2.5 and associated trace elements in Guangzhou, China. *Sci Total Environ*, 366(1), 124-135. doi: 10.1016/j.scitotenv.2005.09.004